

waterworks. A plug or stopcock controlling the supply of water to such fire escapes shall be placed near the edge of the sidewalk, and shall be under the sole control of the fire department. The tops of the ladders shall not be closed.

Limit of time.
Ib., Sec. 2.

SEC. 466. All owners, agents or occupants of buildings for which, by the terms of this ordinance fire escapes are required to be provided, are hereby required to provide the same according to the provisions hereof within ninety days after the same shall go into effect.

Penalty.
Ib., Sec. 3.

SEC. 467. Any person violating the provisions of this ordinance, and any person meddling or interfering with any plug or stopcock, which by the provisions of section 465 are placed under the exclusive control of the fire department, shall be punished by fine not exceeding two hundred dollars, or by imprisonment not exceeding thirty days.

AERIAL TRUCKS.

B 121.
Aug. 7, 1891.

SEC. 468. The Board of Public Works of the City of Jacksonville are hereby authorized to expend the sum of not exceeding three thousand dollars for the purchase of aerial trucks of the latest improved pattern, the said money to be paid out of the money coming under their control for such purposes.

FIRE PROTECTION.

Storing
inflammable
material
prohibited.
F 5, Sec. 13.
May 20, 1901.

SEC. 469. It shall be unlawful for any person, firm or corporation to store or keep or cause to be stored or kept within the metal-roof limits of the City of Jacksonville, as fixed by ordinance, at any one time, in any one place or building, under their control, exceeding five cases of gasoline, benzine or naphtha, or exceeding one hundred and seventy-five gallons of petroleum product, kerosene, or other illuminating oils; and it shall be unlawful for any person, firm or corporation to store or keep, or cause to be stored or kept, within the limits of the City of Jacksonville, inside the metal-roof limits as fixed by ordinance, exceeding five cases of gasoline, benzine or naphtha or exceeding one hundred and seventy-five gallons of petroleum, petroleum products, kerosene or other illuminating oils, unless the same shall be kept in a fire-proof building of stone or brick, covered by a roof of metal, asphalt, asbestos or slate, and constructed in such manner that no opening or outlet in the walls thereof shall be less than three feet above the ground floor; and provided further, That all such openings shall be provided with tight-fitting doors and shutters, covered with metal on the outside, unless special permission of the Inspector and the Committee